


Butterfly Valves

COMPANY

SHIELD FIRE SAFETY & SECURITY LTD

Unit 3, Endeavour Dr
Basildon, SS14 3WF United Kingdom

EX6710

Trademark and/or Tradename: 

Note: For additional marking information, refer to the [Guide Information Page](#).

View model for additional information

Butterfly Valve, Model(s): [SD-300G-BV](#), [SD-300W-BV](#), [SDBB-G](#), [SDBB-G300](#), [SDBB-T](#), [SDBB-T300](#), [SDBV-G \(sizes 2-1/2, 3, 4, 6 & 8 in\)](#), [SDBV-G300 \(sizes 2-1/2, 3, 4, 6 & 8 in\)](#), [SDBV-GFC-175](#), [SDBV-GFC-200](#), [SDBV-GFC-250](#), [SDBV-GFC-300](#), [SDBV-GFC-360](#), [SDBV-GFC-360MS](#), [SDBV-GFC-PN16](#), [SDBV-GFC-PN25](#), [SDBV-GTEC-175](#), [SDBV-GTEC-200](#), [SDBV-GTEC-250](#), [SDBV-GTEC-300](#), [SDBV-GTEC-PN16](#), [SDBV-LEC-10K](#), [SDBV-LEC-175](#), [SDBV-LEC-200](#), [SDBV-LEC-250](#), [SDBV-LEC-300](#), [SDBV-LEC-360](#), [SDBV-LEC-360MS](#), [SDBV-LEC-PN10](#), [SDBV-LEC-PN16](#), [SDBV-LEC-PN25](#), [SDBV-LTEC-10K](#), [SDBV-LTEC-175](#), [SDBV-LTEC-200](#), [SDBV-LTEC-250](#), [SDBV-LTEC-300](#), [SDBV-LTEC-PN10](#), [SDBV-LTEC-PN16](#), [SDBV-TT](#), [SDBV-TT](#), [SDBV-W \(sizes 2-1/2, 3, 4, 6 & 8 in\)](#), [SDBV-W300 \(sizes 2-1/2, 3, 4, 6 & 8 in\)](#), [SDBV-WEC-10K](#), [SDBV-WEC-175](#), [SDBV-WEC-200](#), [SDBV-WEC-250](#), [SDBV-WEC-300](#), [SDBV-WEC-360](#), [SDBV-WEC-360MS](#), [SDBV-WEC-PN10](#), [SDBV-WEC-PN16](#), [SDBV-WEC-PN25](#), [SDBV-WTEC-10K](#), [SDBV-WTEC-175](#), [SDBV-WTEC-200](#), [SDBV-WTEC-250](#), [SDBV-WTEC-300](#), [SDBV-WTEC-PN10](#), [SDBV-WTEC-PN16](#)

[Last Updated](#) on 2024-12-06

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2025 UL LLC."

Check Valves

COMPANY

SHIELD FIRE SAFETY & SECURITY LTD

Unit 3, Endeavour Dr
Basildon, SS14 3WF United Kingdom

EX6721

Trademark and/or Tradename: "SD", "SHIELD", , , , , 

Note: For additional marking information, refer to the [Guide Information Page](#).

View model for additional information

Split-clapper, Model(s): [SD-DDNRV200](#), [SD-DDNRV250](#), [SD-DDNRV300](#), [SD-DDNRV-PN10](#), [SD-DDNRV-PN16](#)

Swing, Model(s): [SD-NRV200CV](#), [SD-NRV200FF-D](#), [SD-NRV200GG-D](#), [SD-NRV250CV](#), [SD-NRV250GG-D](#), [SD-NRV300FF-D](#), [SD-NRV300FF-D2](#), [SD-NRV300GG-D](#), [SD-NRV350FF-D2](#), [SD-NRV350FG-D2](#), [SD-NRV350GF-D2](#), [SD-NRV350GG-D2](#), [SD-NRV-360FF](#), [SD-NRV-360GG](#), [SD-NRVGG-PN10](#), [SD-NRVGG-PN16](#), [SD-NRV-PN16](#)

[Last Updated](#) on 2024-12-06

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2025 UL LLC."

Extinguishing System Attachments

COMPANY

SHIELD FIRE SAFETY & SECURITY LTD
 Unit 3, Endeavour Dr
 Basildon, SS14 3WF United Kingdom

S9078

Supervisory switches, SD-SVS-OSYJM

SPRINKLER SYSTEM ALARM INITIATING DEVICES

Wet pipe, paddle type

Model	Size In.	Pipe Schedule	Max System Pressure psig
SD-WFD10T	1.00	10 thru 40	175
SD-WFD12T	1.25	10 thru 40	175
SD-WFD15T	1.50	10 thru 40	175
SD-WFD20T	2.00	10 thru 40	175
SD-WFD20	2	10 thru 40	175
SD-WFD25	2.5	10 thru 40	450
SD-WFD30	3	10 thru 40	450
SD-WFD40	4	10 thru 40	450
SD-WFD50	5	10 thru 40	450
SD-WFD60	6	10 thru 40	450
SD-WFD80	8	10 thru 40	450
SD-WFD100	10	10 thru 40	300
SD-WFD-JM	2.00	10 through 40	365
	2.5	10 through 40	365
	3.0	10 through 40	365
	4.0	10 through 40	365
	5.0	10 through 40	365
	6.0	10 through 40	365
	8.0	10 through 40	365

SUPERVISORY SIGNAL INITIATING DEVICES

Supervisory switches

Model	Oper Pressure psig	Max System Pressure psig
SD-SVS OSY-1	N/A	N/A
SD-SVS OSY-2	N/A	N/A
SD-SVS OSY-3	N/A	N/A
SD-SVS IP-1	N/A	N/A
SD-SVS IP-2	N/A	N/A
SD-SVS IP-3	N/A	N/A

SPRINKLER SYSTEM ALARM INITIATING DEVICES

Wet pipe, paddle type

Model	Size In.	Pipe Schedule	Max System Pressure psig
SD-WFD10TW	1	10 thru 40	450
SD-WFD12TW	1.25	10 thru 40	450
SD-WFD15TW	1.5	10 thru 40	450
SD-WFD20TW	2	10 thru 40	450
SD-WFD20W	2	10 thru 40	450
SD-WFD25W	2.5	10 thru 40	450
SD-WFD30W	3	10 thru 40	450
SD-WFD40W	4	10 thru 40	450
SD-WFD50W	5	10 thru 40	450
SD-WFD60W	6	10 thru 40	450
SD-WFD80W	8	10 thru 40	225

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2025 UL LLC."

Drain Fittings, Special Type

COMPANY

SHIELD FIRE SAFETY & SECURITY LTD

Unit 3, Endeavour Dr
Basildon, SS14 3WF United Kingdom

EX6708

Trademark and/or Tradename: "SD" ,  ,  , 

Note: For additional marking information, refer to the [Guide Information Page](#).

View model for additional information

Model(s): [SD-A61](#), [SD-TDV50G](#), [SD-TDV50G-E](#), [SD-TDV50G-E](#), [SD-TDV50T](#), [SD-TDV50T-E](#), [SD-TDV50T-E](#)

Last Updated on 2023-10-06

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."


Gauges, Pressure

COMPANY

SHIELD FIRE SAFETY & SECURITY LTD

Unit 3, Endeavour Dr
Basildon, SS14 3WF United Kingdom

EX6714

Trademark and/or Tradename: 

Note: For additional marking information, refer to the [Guide Information Page](#).

View model for additional information

Bourdon tube type, Model(s): [Model SD-P](#), [SD-P1](#), [SD-P1](#), [SD-P2](#), [SD-P3](#)

[Last Updated](#) on 2024-12-06

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2025 UL LLC."