

**Certificated Products**

		<b>LPCB Ref. No.</b>
Xenex 8 13270-08LB	7.11 Delays of actioning to outputs to fire alarm routing equipment 10 Test condition 8 zone conventional control and indicating equipment (Xenex brand) Certified with the following options from EN 54 Part 2: 1997 7.8 Output to fire alarm devices 7.11 Delays of actioning to outputs to fire alarm routing equipment 10 Test condition	042x/04

**Gulf Alarm UK Limited**

Office 32, 19-21 Crawford Street, London W1H 1PJ, United Kingdom  
 E-mail: [info@gulfalarm.com](mailto:info@gulfalarm.com) • Website: [www.gulfalarm.com](http://www.gulfalarm.com)

Certificate No: 1330h-(cl-5) to EN54-2: 1997 + A1: 2006 & EN54-4: 1997 + A1: 2002 + A1: 2006

**Control and indicating equipment**

**Approved Products**

		<b>LPCB Ref. No.</b>
GA7004	1 to 4 loop Intelligent Addressable Control and Indicating Equipment Incorporating the following modules: 7010200004 TX7004 Mother Board 7020100022 TX7004 Main Board 7010700017 TX7004 Loop Board 7010400011 TX7004 Power Management Board 7010600019 TX7004 Communication Board 7010400012 TX7004 Power Wiring Board PDF-150-27.5 Power Supply Unit 7021300007 TX7004 Key Board 7020800009 TX7004 Led Board 7010300010 TX7004 Regional Display Board 814400002 TX6940E Printer Module  Certified with the following options with requirements from EN54-2: 7.8 Output to fire alarm device(s) 7.10.1 Output to fire protection equipment - Type A 7.11 Delays to outputs 7.12.1 Dependencies on more than one alarm signal - Type A 7.12.2 Dependencies on more than one alarm signal - Type B 7.13 Alarm counter 9.5 Disabling of each address point 10 Test condition Notes: 1. The scope of the approval does not include the operation of the network functionality 2. The product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.	1330h/01